

certificate
no. **BAU 19055**
dated 2019-05-13

Translation In any case, the German original shall prevail.

EuroTest Certificate

Name and address of the holder of the certificate: (customer) LTW Tiefbauvertriebs GmbH
Holter Weg 11
41836 Hückelhoven
GERMANY

Product designation: **Slide rail paneel - VS 100**

Type: VS 100
for paneel lengths of up to: L= 4,02 m
for paneel heights of up to: 2,38 m
for on-stick paneel heights of up to: 1,37m und 1,57 m

Testing based on: EN 13331-2:2002
EN 13331-1:2002
DIN 4124:2012

Test report:


Further details: The permissible earth pressure loading is to be taken from the manufacturers manual as a function of the system dimensions. According to assembly instructions of manufacturer. Additional certificate to number: 14064-ET.

The manufacturer is also Certificate holder

The type tested complies with the test basis specified above.
The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.

The present certificate including the right to affix the ET-mark is valid until: **2024-03-17**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.



Dipl.-Ing. (FH) Franz Welsch
Deputy Head of Certification Body

